



Institut Français du  
Textile et de l'Habillement

This document is the translation of the French  
certificate n° 21-02127 L on June 24<sup>th</sup> 2021 delivered  
by IFTH.

**MATERIAL REACTION TO FIRE CLASSIFICATION**  
**REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE**  
**REGULATION DATED NOVEMBER 21<sup>ST</sup>, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)**

Valid five years from issue date

**CERTIFICATE N° 21-02127 L**

And appendices of 5 pages

**MATERIAL presented by:**

SENFA  
1 RUE DE MORAT  
BP 8  
67601 SELESTAT CEDEX  
FRANCE

**TRADE NAME:**

SENFA DIAMOND / SENFA GOLD / SENFA SILVER

**BRIEF DESCRIPTION:**

100 % polyester fabric with fireproofed acrylic coating on both sides  
Nominal surface weight: 245 ± 5 g/m<sup>2</sup>  
Nominal thickness: 0.30 ± 0.02 mm  
Colours: Various

**TEST REPORT:**

N° 21-02127 E1V1 on June 24<sup>th</sup> 2021

**TESTS:**

Electrical burner test  
Flame persistence test

**CLASSIFICATION:**

**M 1**

**CLASSIFICATION DURATION (article 5 of appendix 2) :** limited 12 months from the date of the setting of the material in the regulated building, shielded from external weather conditions (material no washable and not suitable for dry cleaning)

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on June 24<sup>th</sup> 2021

Olivier PALLAS  
Engineer Tests and Trials