

This document is the translation of the French certificate n° 24-00595 L delivered by IFTH on the March 29th 2024

**MATERIAL REACTION TO FIRE CLASSIFICATION REPORT  
PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE REGULATION  
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)**

Valid five years from issue date

**CERTIFICATE N° 24-00595 L**

And 1 Appendix of 5 pages

MATERIAL presented by:

SENFA  
1 RUE DE MORAT  
67601 SELESTAT CEDEX  
FRANCE

TRADE NAME:

SENFA ECHOSIDE 60

BRIEF DESCRIPTION:

100 %polyester fabric with inherent flame retardant PVC coating on both sides

Nominal surface weight : 230 ± 10 g/m<sup>2</sup>

Nominal thickness : 0.60 mm

Colours : White

TEST REPORT :

N° 24-00595 E1V1 on the March 29th 2024

TESTS :

Electrical burner test  
Flame persistence test

CLASSIFICATION

**M1**

Classification valid for any application for which the product is not subjected to the CE marking of the Construction products


CLASSIFICATION DURATION (article 5 of appendix 2) : unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the March 29th 2024

  
Olivier PALLAS  
Tests and Trials Engineer